



DC POWER CENTER



BATTERY TEST



1	<input type="radio"/>	<input type="radio"/>	DC MAIN
2	<input type="radio"/>	<input type="radio"/>	_____
3	<input type="radio"/>	<input type="radio"/>	_____
4	<input type="radio"/>	<input type="radio"/>	_____
5	<input type="radio"/>	<input type="radio"/>	_____
6	<input type="radio"/>	<input type="radio"/>	_____
7	<input type="radio"/>	<input type="radio"/>	_____
8	<input type="radio"/>	<input type="radio"/>	_____

bass
 Bass Products, Inc., Salem, MA, USA

1] DC Main Circuit Breaker (Select one)

- 50A CB "A"
- None (install branch breaker)

2] Branch Circuit Requirements (Office use only)

- 2.5A CB _____
- 5A CB _____
- 10A CB _____
- 15A CB _____
- 20A CB _____
- 25A CB _____
- 30A CB _____
- 40A CB _____
- 50A CB _____
- 10A PB CB _____
- 15A PB CB _____
- M-A Sw _____
- Hole Plug _____
- Total (w/main 8) _____

3] Optional 12V DC LED's (8) (Select one)

- Yes (L)
- No

SEE PRICE LIST FOR OPTIONS IN ().

Option Description:

L Red LED indicator lights installed in all circuit breaker positions. Each LED lights when the corresponding circuit breaker is turned on. Priced per panel.

BRANCH BREAKER SELECTION:

20 LEGEND Select from standard nameplates. (Label sheet 79-7111 supplied if no selection is made.)
 FILL IN IF OPTIONAL LED INDICATOR LIGHT REQUIRED.